



PGG Energy Pty Ltd

PO Box 4100
Kingsway West
Phone 1300 744 674
Fax
Mobile
Email peter@pggenergy.com.au
Homepag <https://www.pggenergy.com.au>

Proprietor
Sample

Plant



L O C A T I O N

Measurement

Type Flue gas test
Start 12/05/2020 1:23:21 PM
End 12/05/2020 1:23:21 PM
Device testo 340
Serial number 61940338

12/05/2020 1:23:21 PM	Date / time
6.89	% O2
0	ppm CO
8.00	% CO2
48.8	% ExAir
0.0000	ratio
24.0	ppm NOx
20	ppm NO
4.0	ppm NO2
81.1	% Effg
89.4	% Effn
27.4	°C AT
198.1	°C FT
30.5	°C ltemp
-	mbar Drght
-	mbar deltap1
-	mbar deltap2
0	ppm H2